

## Axel Schwendt

---

**From:** Winter, Maurice [MauriceW@dep.nyc.gov]  
**Sent:** Wednesday, December 10, 2008 3:19 PM  
**To:** Axel Schwendt  
**Subject:** RE: 08DEPTECH339Q - 179-26 Jamaica Avenue Queens

Approved for a change to use of a 15 mil GSE HD vapor barrier.

Maurice

---

**From:** Axel Schwendt [mailto:ASchwendt@akrf.com]  
**Sent:** Friday, December 05, 2008 1:56 PM  
**To:** Winter, Maurice  
**Subject:** 08DEPTECH339Q - 179-26 Jamaica Avenue Queens

Maurice,

Storage Deluxe, the owner and developer of the 179-26 Jamaica Avenue site in Queens, is requesting approval for a change in the brand of vapor barrier to be installed at the site. The DEP-approved RAP included the installation of a 15 mil GSE HD geomembrane. Due to the difficulties and excessive costs associated with the installation of this vapor barrier, Storage Deluxe requests that you approve the use of a 15 mil Stego® Wrap Vapor Barrier as an alternative. The specifications for this vapor barrier are attached, along with a letter detailing our request. A hard copy of these materials is being sent to you via Fed Ex.

Please let me know if you have any questions or concerns.

Best regards,  
Axel

Axel Schwendt  
Technical Director  
AKRF, Inc.  
440 Park Avenue South  
New York, NY 10016  
(646) 388-9529 (PH)  
(212) 726-0942 (FAX)